

AIR CONDITIONING SYSTEMS

WALL MOUNTED UNIT

- **PRODUCT FICHE**

**MODELS:**

L6VI32-09WF/L6VO32-09

L6VI32-12WF/L6VO32-12

L6VI32-18WF/L6VO32-18

L6VI32-24WF/L6VO32-24

Contents

English.....3

PRODUCT FICHE

NAME OR TRADEMARK: INVENTOR

	L6VI32-09WF/ L6VO32-09	L6VI32-12WF/ L6VO32-12	L6VI32-18WF/ L6VO32-18	L6VI32-24WF/ L6VO32-24
Sound power level at standard rating conditions (indoor/outdoor) (dB(A))	55/63	55/63	56/64	60/67
Refrigerant/Mass (Kg)	R32/0.55	R32/0.55	R32/1.08	R32/1.42
GWP	675	675	675	675
CO ₂ equivalent (tonnes)	0.37	0.37	0.73	0.96
SEER	6.2	6.1	7.2	6.1
Energy class in cooling mode	A++	A++	A++	A++
Annual electricity consumption in cooling [1] [KWh/y]	158	206	253	402
Design load in cooling mode (P design) [KW]	2.8	3.6	5.2	7.0
SCOP (average heating season)	4.0	4.0	4.0	4.0
Energy class in heating (average season)	A+	A+	A+	A+
Annual electricity consumption in heating (average season) [2] [KWh/y]	910	945	1436	1682
Warmer heating season	-	-	-	-
Colder heating season	-	-	-	-
Design load in heating mode (P design average season) [KW]	2.6	2.7	4.1	4.8
Declared capacity at reference design condition (heating average season) [KW]	1.996	2.019	3.349	3.838
Back up heating capacity at reference design condition (heating average season) [KW]	0.604	0.681	0.751	0.962

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to [675]. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be [675] times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Contains fluorinated greenhouse gases.

[1] [2] Energy consumption "XYZ" kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

Note: Please check the model information above according to the model name on the nameplate.



AIR CONDITIONING SYSTEMS

WALL MOUNTED UNIT



V:2.0.062024



Scan here to download the latest version of this manual.



Manufacturer: INVENTOR A.G. S.A.

24th km National Road Athens - Lamia & 2 Thoukididou Str., 145 65, Ag. Stefanos, Greece

Tel.: +30 211 300 3300, Fax: +30 211 300 3333